Certificate of Compliance

Certificate Number 240610-EX15451

Report Reference EX15451, December 22, 2009

Issue Date 2010 June 24



Issued to: MAS DAF MAKINA SANAYI AS

Atasehir Bulvari Atacarsi Kat 4 No 52

34758 Atasehir Istanbul, Turkey

This is to certify that representative samples of

Centrifugal Fire Pumps, End Suction Model Designation: YNM 525, YNM 825 and YNM 1531

Have been investigated by Underwriters Laboratories in accordance with

the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard for Centrifugal Stationary Pumps for Fire-Protection Service, UL 448.

In accordance with the National Fire Protection Association Standard for the

Installation of Stationary Pumps for Fire Protection, NFPA 20.

Additional Information: See UL On-line Certification Directory at <u>WWW.UL.COM</u> for additional information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at http://www.ul.com/global/eng/pages/corporate/contactus/